

Nederlands Meetinstituut

EC type-approval certificate

Number **T6904** revision 0
Project number 511163
Page 1 of 3

Issued by NMI Certin B.V.
Hugo de Grootplein 1
3314 EG Dordrecht
The Netherlands

Notified Body Number 0122

In accordance with The Council Directive 90/384/EEC on non-automatic weighing instruments.

Applicant Bosche GmbH & Co. KG
Reselager Rieden 3
D-49401 Damme
Germany

In respect of A class **(III)**, electronic, **non-automatic weighing instrument**.
Manufacturer : Bosche
Type : AWI-P (Price computing scale)
AWI-C (Counting scale)

Characteristics $n \leq$ the number of scale intervals mentioned in the test certificates involved.
In the description number T6904 revision 0 further characteristics are described.

Valid until 6 February 2016

Description and documentation The instrument is described in the description number T6904 revision 0 and documented in the test certificates involved.

Dordrecht, 6 February 2006
NMI Certin B.V.

1/a

Ing. C. Oosterman
Manager Product Certification

NMI Certin B.V.
Hugo de Grootplein 1, 3314 EG Dordrecht
P.O. Box 394, 3300 AJ Dordrecht, NL
phone +31 78 6332332
fax +31 78 6332309
certin@nmi.nl
www.nmi.nl

Parties concerned can lodge objection against this decision, within six weeks after the date of submission, to the general manager of NMI B.V. (see "Regulation objection and appeal against decisions of NMI B.V.")

NMI Certin B.V., chamber o.c. no. 27.233.418

This document is issued under the provision that no responsibility is accepted and that the applicant gives warranty for each responsibility against third parties.

Reproduction of the complete document is allowed. Parts of the document may only be reproduced after written permission.



1 General information about the non-automatic weighing instrument

All properties of the non-automatic weighing instrument, whether mentioned or not, may not be in conflict with the legislation.

1.1 Essential parts

Indicator:

Manufacturer	Type	Test certificate number
Bright Advance Corporation	SB510, SB710 (price computing scales) SB520, SB720, SB721 (piece counting scales)	TC6304

Any load cell(s) may be used for instruments under this EC type-approval certificate, provided the following conditions are met:

- There is a respective OIML Certificate of Conformity (R60) or a test certificate (EN45501) issued for the load cell by a Notified Body responsible for type examination under Directive 90/384/EEC.
- The certificate contains the load cell types and the necessary load cell data required for the manufacturer's declaration of compatibility of modules (WELMEC 2, Issue 4, 2004, No 11), and any particular installation requirements. A load cell marked **NH** is allowed only if humidity testing to EN45501 has been conducted on this load cell.
- The compatibility of load cells and indicator is established by the manufacturer by means of the compatibility of modules form, contained in the above WELMEC 2 document, at the time of EC verification or declaration of EC conformity of type.
- The load transmission must conform to one of the examples shown in the WELMEC guide for load cells (WELMEC 2.4).

1.2 Essential characteristics

The essential characteristics are described in the test certificates involved.


1.3 Essential shapes

The data plate is secured against removal by sealing or will be destroyed when removed.

To secure components that may not be dismantled or adjusted by the user, the non-automatic weighing instrument has to be secured in a suitable manner on the locations indicated in the test certificates involved. If present, the load cell cable or the junction box has to be secured in an suitable manner.

The securing component has to bear either:

- A mark of the manufacturer laid down in a notified body approved quality system (Annex II of the directive 90/384/EEC), or
- An official mark of a Member State of the EEC, or another party to the EEA agreement.



1.4 Conditional parts

The non-automatic weighing instrument may be equipped with peripheral equipment which is used for the applications listed in article 1(2)(a) of the EC Directive (90/384/EEC), if the peripheral equipment is certified to be connected to an EC type-approved non-automatic weighing instrument by a Notified Body appointed to certify non-automatic weighing instruments according to paragraph I of Annex II of the EC directive on Non-Automatic Weighing Instruments. The non-automatic weighing instrument is fitted with a leveling device and a level indicator, unless the instrument is installed in a fixed position. The level indicator has a sensitivity of at least 2 mm for a tilt of 2/1000.

1.5 Conditional characteristics

The conditional characteristics are described in the test certificates involved.

1.6 Non-essential parts

The non-automatic weighing instrument may be connected to non-essential devices, for example but not limited to bar code readers, foot switches, second display's and cash drawers, provided that:

- They do not present primary data used for purposes mentioned in article 1(2)(a) of the EC Directive (90/384/EEC) unless the "preliminary observations" in Annex 1 of this directive is satisfied.
- They do not lead to an instrument having other essential characteristics than those fixed by this type-approval document.

2 Approval conditions

See chapter 1.3, essential shapes.

3 Seals and verification marks

See chapter 1.3, essential shapes.

4 CE-mark of conformity and inscriptions

The marks, facilities for the marks and the inscriptions on the non-automatic weighing instrument fulfill the requirements of article 1 of Annex IV.